

Attestation of Conformity

Attestation No: **SHA-AoC-230022**

Applicant Name & Address: Hangzhou Livoltek Power Co., Ltd.
1418-35 Moganshan Road, Shangcheng Industrial Zone, Hangzhou,
Zhejiang Province, China

Factory Name & Address: Afore New Energy Technology (Shanghai) Co., Ltd.
Building 7, No.333 Wanfang Rd, Minhang District, Shanghai. China.
201112

Product Description: ON-GRID SOLAR INVERTER

Brand Name: **LIVOLTEK**

Model: GT3-17KL-D, GT3-20KL-T, GT3-25KL-T, GT3-30KL-Q,
GT3-30K-D2, GT3-36K-T2, GT3-40K-T2, GT3-50K-T2, GT3-60K-Q2

Characteristics: See appendix for details

Standards: EN 62109-1:2010; EN 62109-2:2011

EU Directive: the Low Voltage Directive (LVD) (2014/35/EU)

Test Report No: 231200186SHA-001, 231200186SHA-002

Issued by: Intertek Testing Services Ltd. Shanghai
West Area, 2nd Floor, No. 707, Zhangyang Road, China (Shanghai)
Pilot Free Trade Zone, Shanghai, P. R. China

Issue date: 2023-12-12

This is to attest that the Technical Construction File for the product listed above has been evaluated against the Essential Safety Requirements of Annex I of the Low Voltage Directive (2014/35/EU). This Attestation can be used in support of the Manufacturers Declaration of Conformity on affixing the CE mark. Product conformity to CE marking is not assured until all other applicable EU Regulations are met in full.

Signature

Name: Qiao Qiao



APPENDIX: Attestation of Conformity

This is an Appendix to Attestation of Conformity Number: SHA-AoC-230022

Ratings & Principle Characteristics:

Specifications table				
Model	GT3-17KL-D	GT3-20KL-T	GT3-25KL-T	GT3-30KL-Q
PV input				
P _{pv} Max(W)	25500	30000	37500	45000
V _{max} PV (Vdc) (absolute Max.)	750	750	750	750
I _{sc} PV (absolute Max.) (A)	48 x2	48x3	48x3	48x4
Number MPP trackers	2	3	3	4
Number input strings	2/3	2/2/2	2/2/3	2/2/2/2
Max. PV input current (A)	38x 2	38 x3	40x3	38 x4
MPPT voltage range (Vdc)	200-700	200-700	200-700	200-700
Vdc range @ full power (Vdc)	310-600	320-600	300-600	300-600
AC Grid (output)				
Normal AC Voltage (VAC)	3P+PE/3P 133/230			
Frequency (Hz)	50			
Normal AC Current (A)	42.7	50.2	62.7	75.2
Max. cont. output current (A)	48	60	80	96
Normal Power (W)	17000	20000	25000	30000
Rated Apparent Power (VA)	17000	20000	25000	30000
Max. cont. Power (W)	17000	20000	25000	30000
Max. cont. Apparent Power (VA)	17000	20000	25000	30000
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP65			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated			
Oversvoltage category	OVC III (AC Main), OVC II (PV)			
Software version	DSP:V06 CPLD:V06 HMI:V06			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

APPENDIX: Attestation of Conformity

This is an Appendix to Attestation of Conformity Number: SHA-AoC-230022

Ratings & Principle Characteristics:

Specifications table					
Specifications table					
Model	GT3-30K-D2	GT3-36K-T2	GT3-40K-T2	GT3-50K-T2	GT3-60K-Q2
PV input					
P _{pv} Max(W)	45000	54000	60000	75000	90000
V _{max} PV (Vdc) (absolute Max.)	1100	1100	1100	1100	1100
I _{sc} PV (absolute Max.) (A)	48 x 2	48 x 3	48 x 3	48 x 3	48 x 4
Max. PV input current / strings (A)	38 x 2	38 x 3	38 x 3	40 x 3	38 x 4
Number MPP trackers	2	3	3	3	4
Number input strings	2/3	2/2/2	2/2/2	2/2/3	2/2/2/2
MPPT voltage range (Vdc)	200-1000	200-1000	200-1000	200-1000	200-1000
Vdc range @ full power (Vdc)	500-850	500-850	500-850	500-850	500-850
AC Grid output					
Normal AC Voltage (VAC)	3P+N+PE/3P+PE 230/400				
Frequency (Hz)	50				
Normal AC Current (A)	43.5	52.2	58	72.5	87
Max. cont. output current (A)	48	60	65	80	96
Normal Power (kW)	30	36	40	50	60
Rated Apparent Power (kVA)	30	36	40	50	60
Max. cont. Power (kW)	30	36	40	50	60
Max. cont. Apparent Power (kVA)	30	36	40	50	60
Power factor	1 (-0.8~+0.8 adjustable)				
Others					
Ingress protection (IP)	IP65				
Protective class	Class I				
Temperature (°C)	-25°C to +60°C (Derating 45°C)				
Inverter Isolation	<input checked="" type="checkbox"/> Non-isolated				
Overvoltage category	OVC III (AC Main), OVC II (PV)				
Software Version	DSP: V06 CPLD: V06 HMI: V06				

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.